

# 2016 Annual Drinking Water Quality Report

## Is my water safe?

Yes it is and we are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

## Do I need to take special precautions?

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## Where does my water come from?

Jetty Creek, a surface water source, has been used by the City of Rockaway Beach since 1968. Ground water sources include a well at Manhattan Beach as well as a well in Nedonna.

## Source water assessment and its availability

A source assessment has been completed and is available from City Hall upon request, or online at the City's website at [www.rockawaybeachor.us](http://www.rockawaybeachor.us).

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## How can I get involved?

If you have any questions concerning this report or the water system, please contact Public Works Director Luke Shepard at 503-355-2982. You may also address issues at any of the regularly scheduled City Council meetings held on the second Wednesday of every month at 6:00 p.m. at Rockaway Beach City Hall, 276 S. Hwy 101.

## Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rockaway Beach Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Current Events and Upgrades

In December of 2016 the Water Treatment Plant at Jetty Creek received a major upgrade. The old filter skids were replaced with brand new, more modern and efficient filters. These new filters will allow for less maintenance and downtime, yet still deliver the highest quality finished water possible. The new filters will also cut down on chemical costs due to the higher efficiency. Much of the installation labor was done by City staff which lowered the upgrade costs.

---

## Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

### For more information please contact:

Luke Shepard  
P.O. Box 5  
Rockaway Beach, OR 97136  
Phone: (503)355-2982  
Fax: (503)355-3388  
E-Mail: [lukeshepard@rockawaybeachor.us](mailto:lukeshepard@rockawaybeachor.us)  
Website: [www.rockawaybeachor.us](http://www.rockawaybeachor.us)

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfectant By-Products</b>								
2016								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Halooacetic Acids (HAA5) (mg/L)	NA	60	0.00975	0.0042	0.0184	2016	No	By-product of drinking water chlorination due to the reaction of organics with the chlorination.
TTHMs [Total Trihalomethanes] (mg/L)	NA	80	0.043825	0.0411	0.0483	2016	No	By-product of drinking water disinfection due to the reaction of organics with chlorination.
2016								
Lead - source water (ppm)		0.01	0.01(M PL)	NA	NA	2014	No	Corrosion of household plumbing systems; Erosion of natural deposits
Nitrate [measured as Nitrogen] (mg/L)	10	10	1.03	NA	NA	2016	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (optional) (ppm)		MPL	19.7	NA	NA	2014	No	Erosion of natural deposits; Leaching
<b>Microbiological Contaminants</b>								
2016								
Total Coliform (positive samples/month)	0	1	0	NA	NA	2016	No	Naturally present in the environment
Turbidity (NTU)	NA	1	0.09	0.04	0.14	2016	No	Soil runoff
100% of the samples were below the TT value of 1. A value less than 95% constitutes a TT violation. The highest single measurement was 0.13. Any measurement in excess of 5 is a violation unless otherwise approved by the state.								

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Lead - action level at consumer taps (ppb)	0	15	ND	2016	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Copper - action level at consumer taps (ppm)	1.3	1.3	0.221	2016	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Contaminants	MCLG or MRDLG	MCL or MRDL	Your Water	Violation	Typical Source
Arsenic (ppb)	0	10	ND	No	Erosion of natural deposits; Runoff from timber lands.
Asbestos (MFL)	7	7	ND	No	Decay of asbestos-cement water mains; Erosion of natural deposits
Uranium (ug/L)	0	30	ND	No	Erosion of natural deposits

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
MFL	MFL: million fibers per liter, used to measure asbestos concentration
NTU	NTU: Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level